



Rapidrop Global Limited
Rutland Business Park
Newark Road
Peterborough
PE1 5WA
United Kingdom

T: +44 (0)1733 847 510
F: +44 (0)1733 553 958
W: www.rapidrop.com
E: rapidrop@rapidrop.com



DECLARATION OF CONFORMITY No 19072018-1MB

1. Manufacturer of the building product:

**Rapidrop Global Ltd, Rutland Business Park, Newark Road,
Peterborough, England PE1 3WA**

2. Name of the building product:

Rapidrop Grooved Coupling Models 1G, 1GS, 1N, 1NR

3. Statistical classification:

Sprinkler systems SWW 0657-91

4. Application of the building product:

Fire protection systems

5. Technical specification:

Approved to VDS, UL and FM standards

6. Declared parameters of the building product:

Grooved Rigid Coupling Model 1G

Size: DN25 to DN300, Operating temp.: -34°C to 110°C, Material: Ductile Iron, EPDM GASKET

Grooved Rigid Coupling Model 1GS

Size: DN80 to DN100, Operating temp.: -34°C to 110°C, Material: Ductile Iron, EPDM GASKET

Grooved Flexible Coupling Model 1N

Size: DN25 to DN300 Operating temp.: -34°C to 110°C, Material: Ductile Iron, EPDM GASKET

Grooved Flexible Reducing Coupling 1NR

Size: DN65×DN50 to DN200×DN150 Operating temp.: -34°C to 110°C Material: Ductile Iron, EPDM GASKET

7. The name and number of notified body or laboratory and certification number or report of research number, if the notified body took was involved in research process:

FM Approval Guide 2007-2008, UL Approval Guide 2017

VDS: G412020, G412021, G 412022, G 412013

I hereby declare that building products mentioned in point no. 6 are in accordance with technical specification in point 5.

**19/07/2018
Peterborough**


**Marton Beres
Area Sales Manager**



LPCB



ISO 9001:2008 Certified Company